



30-10-10 ft Rule

Table 12.3 – No-Go Zone Distance

Table of minimum clearances (ft) for nominal system voltages (kV)	
kV	Ft
50 (or less)	10
69	11
115	12
230	16
500	25

