



Contractor Bulk Fuel Tank Memo

January 2017

Due to recent and historical incidents involving releases from contractor bulk fuel tanks at Mosaic **Phosphate Facilities**; contractors will no longer be allowed to bring bulk fuel tanks on site without prior approval from Facility Management. Contractor Bulk Fuel Tank Installation, Operation, and Maintenance Guidelines must be agreed upon to be considered for Facility Management approval. Only tanks associated with a specific project will be considered.

All bulk fuel tanks in Florida with a capacity of 550 gallons or over will also maintain compliance with F.A.C. 62-762., with the exception of mobile tanks as defined by F.A.C. 62-762;

(48) "Mobile tank" is:

(a) An AST that is moved to a different location at least once every 180 days; and

1. Has a current valid vehicle registration with the Florida Department of Highway Safety and Motor Vehicles and has current test and inspection markings in accordance with 49 C.F.R. 180.415; or

2. Is designed and constructed to be moved to other service locations, and its relocation within a facility or from site to site is inherent in its use; or

3. Is used for on-site construction activities, provided that the construction activities do not exceed 12 months, or the life of the construction project as long as construction is continuous, and the tanks are removed from the site when the construction is complete; and

(b) Not considered mobile if it is connected to stationary underground or aboveground integral piping, unless associated with the production of an agricultural commodity, provided that the tank is moved to a different location at least once every 180 days.

Please consult with the site EHS Staff for site specific details.