

FIRE PROTECTION SYSTEMS AND EQUIPMENT INSPECTION SCHEDULE

Fire Protection Program
 Inspection Schedule
 Appendix A
 Rev. 6/6/07

Inspection Frequency

		<u>Weekly</u>	<u>Monthly</u>	<u>Quarterly</u>	<u>Semi-annual</u>	<u>Annual</u>	<u>3 year</u>	<u>5 year</u>	<u>6 year</u>	<u>12 year</u>
Equipment to be Inspected	Fire Extinguisher		Visual inspection, good condition, unobstructed, location identified, check pressure guage, seal/pin intact, inspection tag in place, clean, cover available if needed			Monthly plus annual certification consisting of: check made of mechanical parts, condition of hose, nozzle, and vessel, and "weighting or hefting"	Foam Type - Replace foam	CO2, water, foam extinguishers - hydrostatic testing	Dry chemical extinguishers - From date of recharge - Internal maintenance; visual inside; check valve and O rings; replace chemical if needed	Dry chemical extinguisher - hydrostatic test
	Wheeled Extinguisher		Corrosion / abrasion/ damage, check guage, inspect wheels, nozzle, couplings, hose, nozzles		Monthly plus: down tube maintenance, condition of chemical, test regulator					
	Sprinkler Systems		Follow all requirements of NFPA No. 25 - Valves, sprinkler wrenches available, guages, alarm valves, leaks, valves in appropriate correct open / closed position, hydraulic	Monthly plus: regulating control valve, fire connections, alarm device, hydraulic name plate; Testing - water flow alarm, control valves	Quarterly plus: spare sprinklers, visible on sprinklers / pipe / hangers, lubricating valves; Testing: full flow test	Quarterly plus: spare sprinklers, visible on sprinklers / pipe / hangers, lubricating valves; Testing: full flow test		Annual inspection plus internal inspection.		
	CO2 Systems		Visual check, smoke detectors, and all related hardware, damage of cylinders		Monthly plus: all requirements of NFPA No. 2001 and No. 72 - cylinder leak test, discharge pipe			Hydrotesting the cylinders.		
	Halon Systems				Monthly plus: all requirements of NFPA No. 2001, No. 72					
	FM 200				All requirements of NFPA No. 2001, No. 72					
	Hydrants			Blockage, leaks, damage, caps in place, paint & corrosion, grease caps, fillings	Quarterly plus: flowing the water*	Semi-annual plus: all requirements of NFPA No. 25				
	Valves / PIV's	Visual, general condition; Valves / PIV's should be maintained open in a locked position		Visual, general condition, spring torsion tested, stem free movement, good operable condition, open / close sign legible	Quarterly plus: open & close valve fully					
	Fire Pumps	Start diesel motors, check all pressures and gauges (record readings)	Weekly plus: check for leaks, damage, corrosion		Monthly plus: flowing the water*	Semi-annual plus: all requirements of NFPA No. 25				
	Back Flow Prevention				Corrosion, perform annual requirements of NFPA No. 25					
	Foam Carts		Corrosion / abrasion/ damage, check guage, inspect wheels, nozzle, couplings, hose, nozzles			Pressure test fire hose	Replace foam			
	Fire Hose Reels/ Racks/ Carts		Visual, general condition, wheels intact, unobstruted, nozzle available			Visual Inspection; Rerack hose		Pressure test hose 5 years from manufactured date, then every 3 years		
	Fire Hose (New Wales ERT)					Annual pressure test, inspect general condition				
	Fire Truck	Inventory equipment (checklist - fuel, booster tank water level, oil, tires..); fire pump test weekly (functional test)	Equipment inventory (as per checklist)			Fire pump test - full water test				
	Smoke Detectors/ Fire Alarms					Functional test, ground fault test, circuit integrity, load test battery (NFPA				
Snuffers				A local guage/transmitter installed at the last block valve supplying the snuffing steam supply back to the DCS with low pressure alarm and a semi-annual PM in Maximo to be sure the transmitter is						

* "Flowing the water" is not a flow test.